

RE: Lake Petit Dam LLO Update

From: Wesley MacDonald <WMacDonald@Geosyntec.com>

Mon, May 8, 2023 at 9:02 AM EDT (GMT-04:00)

To: Griffin, David <David.Griffin@dnr.ga.gov>

Cc: Jamey Dotson <JDotson@Geosyntec.com>; Scott Auer <sauer@bigcanoepoa.org>; Betsill, Kate <Kate.Betsill@dnr.ga.gov>

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi David,

Here is a brief update on the LLO test. The sluice gate did operate, however, we were unable to fully test the gate last weekend. The plug worked as intended and the gate open and closed, however seven of the stem guides of the gate system showed cracks during the testing process. The gate was fully closed last week and the plug remains in place while we coordinate replacement parts. We have several part replacement approaches under consideration with installers and the gate manufacturer, and we will provide GSD an update on our proposed replacement solution by 30 May 2023.

Thanks,

Wes

Wesley MacDonald, P.E.*

Senior Engineer

*Licensed in TN, AL, GA, and WA

Phone: 423.385.2312

Mobile: 615.830.5139

Geosyntec
consultants

engineers | scientists | innovators

This electronic mail message contains information that (a) is or may be LEGALLY PRIVILEGED, CONFIDENTIAL, PROPRIETARY IN NATURE, OR OTHERWISE PROTECTED BY LAW FROM DISCLOSURE, and (b) is intended only for the use of the Addressee(s) named herein. If you are not the intended recipient, an addressee, or the person responsible for delivering this to an addressee, you are hereby notified that reading, using, copying, or distributing any part of this message is strictly prohibited. If you have received this electronic mail message in error, please contact us immediately and take the steps necessary to delete the message completely from your computer system.

Any professional engineering or geology knowledge, analysis, judgment or recommendations reflected in this email are preliminary and not final unless and until incorporated into a final document signed and stamped by a licensed professional.